


LUMINAIRE PHOTOMETRIC TEST REPORT


NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 72.74 lm/W
MODEL	FW26212424G0015	I <sub>max</sub> (cd)	9453	S/MH (C0/180)		0.31
NOMINAL POWER(W)	24	LOR (%)	100.0	S/MH (C90/270)		0.14
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	1775.8	□ UP, DN (C0-180)		0.6, 68.1
NOMINAL FLUX(lm)	1775.77	CIE CLASS	DIRECT	□ UP, DN (C180-360)		0.8, 30.5
LAMPS INSIDE	1	□ up (%)	1.4	CIBSE SHR NOM		0.00
TEST VOLTAGE(V)	24	□ down (%)	98.6	CIBSE SHR MAX		0.30

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT: lx)



C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

## ZONAL FLUX DIAGRAM

### ZONAL FLUX DIAGRAM:

°	C0	C45	C90	C135	C180	C225	C270	C315	°	□ zone	□ total	%lum, lamp
10	2164	4601	8106	6620	2456	1473	1277	1528	0- 10	434.1	434.1	24.4,24.4
20	727.3	1243	2008	1819	730.0	522.5	485.9	598.7	10- 20	540.8	975.0	54.9,54.9
30	304.6	428.9	635.9	663.1	312.0	260.1	242.8	313.6	20- 30	292.0	1267	71.4,71.4
40	171.3	214.8	271.5	320.8	168.6	145.5	136.0	186.1	30- 40	176.4	1443	81.3,81.3
50	109.6	130.8	147.9	190.0	103.2	89.30	79.93	118.7	40- 50	122.3	1566	88.2,88.2
60	72.76	85.36	87.88	121.0	66.03	53.11	43.44	72.27	50- 60	87.46	1653	93.1,93.1
70	43.11	52.00	53.41	74.17	38.23	25.70	18.10	32.80	60- 70	58.40	1712	96.4,96.4
80	15.95	23.78	27.05	35.81	13.85	4.980	2.115	5.301	70- 80	30.48	1742	98.1,98.1
90	0.1758	4.037	7.115	7.542	0.1742	0.2929	0.3497	0.4971	80- 90	8.833	1751	98.6,98.6
100	0.3635	0.3488	0.3599	0.4971	0.3445	0.4655	0.5354	0.7104	90-100	1.018	1752	98.7,98.7
110	0.6744	0.5854	0.5276	0.7808	0.6458	0.7501	0.8369	1.107	100-110	0.6246	1753	98.7,98.7
120	1.106	0.9403	0.8721	1.257	1.033	1.145	1.343	1.729	110-120	0.9429	1753	98.7,98.7
130	1.787	1.501	1.424	1.913	1.620	1.883	2.384	2.908	120-130	1.365	1755	98.8,98.8
140	3.230	2.601	2.464	3.264	2.795	3.715	5.208	5.986	130-140	2.066	1757	98.9,98.9
150	6.768	5.305	4.931	6.537	5.703	8.160	12.28	13.39	140-150	3.416	1760	99.1,99.1
160	15.03	12.42	11.94	14.63	12.52	17.07	25.99	26.99	150-160	5.430	1766	99.4,99.4
170	29.13	26.53	26.61	30.19	25.57	29.25	38.41	42.10	160-170	6.574	1772	99.8,99.8
180	38.72	40.28	44.18	47.38	39.35	40.68	44.51	47.77	170-180	3.435	1776	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 1521.6 lm

%lum = 85.7%

%lamp = 85.7%

Conical surface Flux(120deg): 1653.2 lm

%lum = 93.1%


%lamp = 93.1%

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### LUMINANCE LIMITATION CURVES

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	3763	7920
80	4296	5910
75	5710	6209
70	5894	5925
65	6695	6475
60	6805	6669
55	7607	7895
50	7977	8732
45	9352	11244


C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

□cc	80%			70%			50%			30%			10%			0
□w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
□fc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio                      Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.99
1.0	1.10	1.07	1.05	1.08	1.05	1.03	1.03	1.01	.00	.99	.98	.96	.96	.94	.93	.91
2.0	1.02	.98	.94	1.00	.96	.93	.97	.94	.91	.93	.91	.89	.91	.88	.87	.85
3.0	.95	.90	.86	.94	.89	.85	.91	.87	.84	.88	.85	.82	.86	.83	.81	.79
4.0	.90	.84	.80	.88	.83	.79	.86	.82	.78	.84	.80	.77	.82	.79	.76	.75
5.0	.85	.79	.75	.84	.78	.74	.82	.77	.73	.80	.76	.73	.78	.75	.72	.70
6.0	.80	.74	.70	.79	.74	.70	.78	.73	.69	.76	.72	.69	.75	.71	.68	.67
7.0	.76	.71	.67	.76	.70	.66	.74	.69	.66	.73	.69	.66	.72	.68	.65	.64
8.0	.73	.67	.64	.72	.67	.63	.71	.66	.63	.70	.66	.63	.69	.65	.62	.61
9.0	.70	.64	.61	.69	.64	.61	.68	.64	.60	.67	.63	.60	.66	.63	.60	.59
10.0	.67	.62	.58	.67	.62	.58	.66	.61	.58	.65	.61	.58	.64	.60	.58	.56



C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### WEC AND CCEC

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

<input type="checkbox"/> cc	80%	70%	50%	30%	10%	0
<input type="checkbox"/> w	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	0
<input type="checkbox"/> fc	20%	20%	20%	20%	20%	0
RCR	RCR:Room Cavity Ratio					Wall Exitance Coefficients(WEC)
0.0						
1.0	.189 .108 .034	.182 .104 .033	.168 .097 .031	.156 .090 .029	.145 .084 .027	
2.0	.178 .097 .030	.171 .094 .029	.160 .089 .028	.150 .084 .026	.140 .079 .025	
3.0	.166 .088 .026	.160 .086 .026	.151 .082 .025	.142 .078 .024	.133 .074 .023	
4.0	.155 .080 .024	.150 .079 .023	.142 .075 .022	.134 .072 .022	.127 .069 .021	
5.0	.145 .074 .021	.141 .072 .021	.134 .070 .020	.127 .067 .020	.120 .064 .019	
6.0	.136 .068 .020	.133 .067 .019	.126 .065 .019	.120 .062 .018	.115 .060 .018	
7.0	.128 .063 .018	.125 .062 .018	.120 .060 .017	.114 .059 .017	.109 .057 .017	
8.0	.121 .059 .017	.119 .058 .017	.114 .057 .016	.109 .055 .016	.104 .053 .016	
9.0	.115 .056 .016	.113 .055 .015	.108 .053 .015	.104 .052 .015	.100 .051 .015	
10.0	.109 .052 .015	.107 .052 .014	.103 .050 .014	.099 .049 .014	.095 .048 .014	

<input type="checkbox"/> cc	80%	70%	50%	30%	10%	0
<input type="checkbox"/> w	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	0
<input type="checkbox"/> fc	20%	20%	20%	20%	20%	0
RCR	RCR:Room Cavity Ratio					Ceiling Cavity Exitance Coefficients(CCEC)
0.0	.201 .201 .201	.172 .172 .172	.117 .117 .117	.067 .067 .067	.022 .022 .022	
1.0	.183 .168 .155	.156 .144 .133	.107 .099 .092	.062 .057 .054	.020 .018 .017	
2.0	.168 .143 .123	.144 .123 .106	.099 .085 .074	.057 .050 .043	.018 .016 .014	
3.0	.155 .124 .100	.133 .107 .087	.091 .075 .061	.053 .044 .036	.017 .014 .012	
4.0	.145 .110 .083	.124 .095 .072	.085 .066 .051	.049 .039 .030	.016 .013 .010	
5.0	.135 .098 .071	.116 .085 .062	.080 .059 .044	.046 .035 .026	.015 .011 .009	
6.0	.127 .089 .061	.109 .077 .053	.075 .054 .038	.044 .032 .022	.014 .010 .007	
7.0	.120 .081 .054	.103 .070 .047	.071 .049 .033	.041 .029 .020	.013 .010 .007	
8.0	.113 .075 .048	.098 .065 .042	.068 .045 .030	.039 .027 .018	.013 .009 .006	
9.0	.108 .069 .043	.093 .060 .038	.064 .042 .027	.037 .025 .016	.012 .008 .005	
10.0	.103 .065 .039	.089 .056 .034	.061 .040 .024	.036 .023 .015	.012 .008 .005	

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### UGR(Unified Glare Rating) Table

NAME: FW26212424G0015					TYPE: FW26212424G0015			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.:					SUR.: 0.026*1			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	14.9	15.8	15.2	16.0	16.2	15.1	16.0	15.4	16.2	16.4	
3H	16.1	17.0	16.4	17.2	17.4	16.1	17.0	16.4	17.2	17.4	
4H	16.6	17.4	16.9	17.7	17.9	16.6	17.4	16.9	17.7	17.9	
6H	16.9	17.7	17.2	17.9	18.2	17.1	17.8	17.4	18.1	18.4	
8H	17.0	17.7	17.3	18.0	18.3	17.3	18.0	17.6	18.3	18.6	
12H	17.0	17.7	17.3	18.0	18.3	17.4	18.1	17.8	18.4	18.7	
4H 2H	15.5	16.3	15.8	16.5	16.8	15.6	16.4	15.9	16.7	16.9	
3H	16.9	17.6	17.3	17.9	18.2	16.9	17.6	17.2	17.9	18.2	
4H	17.5	18.2	17.9	18.5	18.8	17.5	18.1	17.9	18.5	18.8	
6H	17.9	18.5	18.4	18.9	19.3	18.1	18.6	18.5	19.0	19.4	
8H	18.1	18.6	18.5	19.0	19.4	18.3	18.8	18.7	19.2	19.6	
12H	18.1	18.6	18.5	19.0	19.4	18.5	19.0	19.0	19.4	19.8	
8H 4H	17.8	18.3	18.2	18.7	19.1	17.7	18.3	18.2	18.7	19.1	
6H	18.4	18.8	18.8	19.2	19.7	18.5	18.9	18.9	19.3	19.8	
8H	18.5	18.9	19.0	19.4	19.8	18.8	19.2	19.3	19.7	20.1	
12H	18.6	19.0	19.1	19.4	19.9	19.2	19.5	19.7	20.0	20.5	
12H 4H	17.8	18.3	18.2	18.7	19.1	17.8	18.2	18.2	18.6	19.1	
6H	18.4	18.8	18.9	19.3	19.7	18.5	18.9	19.0	19.4	19.8	
8H	18.7	19.0	19.1	19.5	20.0	18.9	19.3	19.4	19.7	20.2	
Variations with the observer position at spacings(CIE Pub.117):											
S = 1.0H	+ 0.3 / - 0.4					+ 0.3 / - 0.4					
1.5H	+ 0.1 / - 0.4					+ 0.3 / - 0.2					
2.0H	+ 0.2 / - 0.5					+ 0.4 / - 0.4					

CIE Pub.117, 1776 lm Total Lamp Luminous Flux Correct (8log(F/F0) = 2.0)  
Area: 0.026 m2

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### UTILIZATION FACTORS TABLE

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	80	72	68	79	72	68	78	72	68	63
0.80	88	81	76	87	80	76	86	80	76	71
1.00	93	86	82	92	86	82	90	86	81	76
1.25	98	92	87	97	91	87	95	90	86	81
1.50	101	95	91	100	94	91	97	93	89	84
2.00	105	100	96	103	99	95	100	96	93	87
2.50	107	102	99	105	101	98	102	98	96	89
3.00	109	105	102	107	103	100	103	100	98	91
4.00	112	108	105	109	106	104	105	103	101	93
5.00	113	110	108	111	108	106	107	105	103	95
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

**ISOCANDELA DIAGRAM**

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:




C Range: 0 - 360DEG  
 C Interval: 22.5DEG  
 Test Speed: HIGH  
 Temperature:25.3DEG  
 Operators:  
 Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
 Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
 Humidity:65.0%  
 Test Distance:5.749m [K=1.0000]  
 Remarks:



### AAI Figure

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### ISOLUX DIAGRAM

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:



C Range: 0 - 360DEG  
 C Interval: 22.5DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators:  
 Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
 Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
 Humidity: 65.0%  
 Test Distance: 5.749m [K=1.0000]  
 Remarks:

### LED Avg.L Report

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	4965
L_0~180 (75) av	4046
L_0~180 (85) av	2135
L_90~270 (65) av	4477
L_90~270 (75) av	3576
L_90~270 (85) av	3634
L_45 (65) av	5807
L_45 (75) av	4542
L_45 (85) av	3698

Standard: GB/T 29293-2012

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

## Planar Illuminance Curve



C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: FW26212424G0015	TYPE: FW26212424G0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

Table--1

UNIT: cd

C (DEG) □ (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699	5699			
5	4540	5585	6678	7927	8596	8790	8030	6729	5046	4167	3537	3083	2902	2941	3222	3760			
10	2164	3143	4601	6752	8106	8375	6620	4605	2456	1805	1473	1319	1277	1335	1528	1920			
15	1342	1902	2733	4201	5105	5249	4033	2855	1418	1081	927	857	838	885	1023	1300			
20	727	958	1243	1720	2008	2099	1819	1467	730	599	522	495	486	518	599	762			
25	496	636	802	1072	1238	1312	1184	1004	502	419	382	364	359	386	451	564			
30	305	362	429	549	636	696	663	596	312	282	260	242	243	262	314	396			
35	237	273	312	375	426	473	471	444	239	226	205	191	193	210	252	323			
40	171	194	215	245	272	308	321	307	169	164	146	137	136	152	186	243			
45	141	159	174	192	210	240	258	249	137	133	119	110	110	125	155	204			
50	110	122	131	139	148	172	190	186	103	100	89.3	82.0	79.9	92.6	119	160			
55	93.3	103	110	114	119	141	158	156	86.5	83.6	73.5	65.3	63.1	74.2	98.9	136			
60	72.8	81.8	85.4	85.3	87.9	105	121	121	66.0	63.0	53.1	45.1	43.4	51.5	72.3	103			
65	60.5	68.8	71.3	70.2	72.1	86.1	101	102	54.3	50.5	41.8	34.0	32.4	38.4	56.0	83.0			
70	43.1	50.5	52.0	51.5	53.4	63.2	74.2	75.4	38.2	32.9	25.7	19.6	18.1	21.5	32.8	53.3			
75	31.6	38.6	40.2	40.5	42.4	50.0	58.1	58.6	28.0	22.1	16.0	11.6	10.3	12.1	19.6	34.5			
80	16.0	21.1	23.8	25.4	27.0	31.8	35.8	33.9	13.8	8.46	4.98	2.73	2.11	2.60	5.30	12.43			
85	7.01	11.4	14.4	16.7	18.2	21.3	22.7	19.1	6.01	2.63	1.06	0.48	0.43	0.63	1.11	3.29			
90	0.18	1.84	4.04	5.96	7.12	8.35	7.54	4.13	0.17	0.27	0.29	0.33	0.35	0.42	0.50	0.47			
95	0.23	0.31	0.71	1.67	2.31	2.70	1.89	0.54	0.22	0.29	0.34	0.38	0.41	0.49	0.54	0.52			
100	0.36	0.37	0.35	0.34	0.36	0.42	0.50	0.60	0.34	0.42	0.47	0.50	0.54	0.63	0.71	0.69			
105	0.48	0.46	0.43	0.40	0.38	0.46	0.59	0.76	0.45	0.52	0.57	0.60	0.64	0.75	0.85	0.83			
110	0.67	0.64	0.59	0.53	0.53	0.63	0.78	1.04	0.65	0.69	0.75	0.79	0.84	0.98	1.11	1.09			
115	0.83	0.78	0.71	0.66	0.65	0.76	0.96	1.26	0.79	0.83	0.89	0.94	1.01	1.18	1.32	1.32			
120	1.11	1.03	0.94	0.88	0.87	1.01	1.26	1.61	1.03	1.08	1.14	1.24	1.34	1.57	1.73	1.73			
125	1.33	1.24	1.13	1.06	1.06	1.22	1.48	1.90	1.23	1.30	1.37	1.51	1.66	1.93	2.10	2.11			
130	1.79	1.65	1.50	1.43	1.42	1.62	1.91	2.49	1.62	1.74	1.88	2.16	2.38	2.74	2.91	2.91			
135	2.22	2.03	1.84	1.76	1.75	1.98	2.33	3.04	1.97	2.17	2.41	2.84	3.17	3.61	3.77	3.71			
140	3.23	2.88	2.60	2.47	2.46	2.73	3.26	4.27	2.80	3.18	3.72	4.56	5.21	5.91	5.99	5.63			
145	4.29	3.78	3.37	3.19	3.18	3.52	4.22	5.54	3.66	4.23	5.07	6.38	7.40	8.39	8.33	7.61			
150	6.77	5.97	5.30	4.99	4.93	5.48	6.54	8.56	5.70	6.64	8.16	10.5	12.3	13.7	13.4	11.89			
155	9.31	8.28	7.43	7.04	6.98	7.67	9.01	11.61	7.80	8.98	11.1	14.4	16.8	18.6	17.9	15.8			
160	15.0	13.6	12.4	12.0	11.9	12.9	14.6	18.2	12.5	14.1	17.1	22.1	26.0	28.3	27.0	23.7			
165	20.2	18.7	17.2	16.8	16.7	17.8	19.9	24.1	16.9	18.6	21.8	27.6	32.8	35.3	33.9	30.1			
170	29.1	28.1	26.5	26.5	26.6	28.0	30.2	34.4	25.6	27.1	29.2	33.6	38.4	41.3	42.1	39.8			
175	35.0	34.6	33.5	34.4	34.8	36.4	37.9	41.8	32.2	33.5	35.3	38.1	40.4	42.7	45.7	46.1			
180	38.7	39.9	40.3	43.3	44.2	45.6	47.4	51.4	39.4	39.4	40.7	42.9	44.5	45.3	47.8	50.9			

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks: