


# LUMINAIRE PHOTOMETRIC TEST REPORT


NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 6.69 lm/W
MODEL	FW26212424B0015	I <sub>max</sub> (cd)	746.1	S/MH (C0/180)	0.35	
NOMINAL POWER(W)	24	LOR (%)	100.0	S/MH (C90/270)	0.15	
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	164.83	□ UP, DN (C0-180)	0.6, 69.8	
NOMINAL FLUX(lm)	164.83	CIE CLASS	DIRECT	□ UP, DN (C180-360)	0.8, 28.8	
LAMPS INSIDE	1	□ up (%)	1.4	CIBSE SHR NOM	0.00	
TEST VOLTAGE (V)	24	□ down (%)	98.6	CIBSE SHR MAX	0.05	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

## ZONAL FLUX DIAGRAM

### ZONAL FLUX DIAGRAM:

°	C0	C45	C90	C135	C180	C225	C270	C315	°	zone	total	%lum, lamp
10	166.6	362.8	685.5	568.3	190.8	107.6	95.90	122.1	0- 10	31.16	31.16	18.9,18.9
20	60.75	105.4	200.8	200.4	66.12	41.20	38.84	51.66	10- 20	48.72	79.88	48.5,48.5
30	28.27	41.46	65.07	72.99	30.73	22.29	21.51	29.93	20- 30	27.39	107.3	65.1,65.1
40	17.60	24.16	31.97	38.96	18.04	13.86	13.33	19.77	30- 40	18.23	125.5	76.1,76.1
50	12.11	15.79	18.96	24.91	11.75	9.269	8.665	13.58	40- 50	13.91	139.4	84.6,84.6
60	8.448	10.75	12.03	16.60	7.901	5.834	4.987	8.533	50- 60	10.59	150.0	91,91
70	5.095	6.853	7.615	10.64	4.670	2.728	1.913	3.699	60- 70	7.342	157.3	95.5,95.5
80	1.882	3.378	4.206	5.529	1.698	0.3916	0.0675	0.3589	70- 80	3.960	161.3	97.9,97.9
90	0.0064	0.6740	1.353	1.374	0.0096	0.0204	0.0267	0.0370	80- 90	1.282	162.6	98.6,98.6
100	0.0268	0.0163	0.0171	0.0370	0.0249	0.0489	0.0605	0.0801	90-100	0.1589	162.7	98.7,98.7
110	0.0670	0.0407	0.0387	0.0708	0.0594	0.0815	0.0992	0.1356	100-110	0.0577	162.8	98.8,98.8
120	0.1110	0.0793	0.0725	0.1231	0.0996	0.1263	0.1573	0.2126	110-120	0.0962	162.9	98.8,98.8
130	0.1780	0.1261	0.1233	0.1877	0.1514	0.1976	0.2687	0.3451	120-130	0.1400	163.0	98.9,98.9
140	0.3043	0.2156	0.2055	0.3016	0.2492	0.3545	0.5400	0.6596	130-140	0.2036	163.2	99,99
150	0.6010	0.4170	0.3868	0.5631	0.4716	0.7131	1.165	1.350	140-150	0.3145	163.5	99.2,99.2
160	1.273	0.9539	0.8992	1.188	0.9720	1.428	2.382	2.557	150-160	0.4716	164.0	99.5,99.5
170	2.347	2.008	1.999	2.373	1.924	2.352	3.208	3.594	160-170	0.5399	164.6	99.8,99.8
180	2.881	3.039	3.452	3.809	2.902	3.061	3.474	3.809	170-180	0.2695	164.8	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 134.26 lm

%lum = 81.5%

%lamp = 81.5%

Conical surface Flux(120deg): 149.99 lm

%lum = 91.0%


%lamp = 91.0%

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### LUMINANCE LIMITATION CURVES

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	438	1302
80	518	916
75	696	912
70	711	842
65	801	900
60	807	910
55	879	1036
50	899	1115
45	1014	1381


C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

□cc	80%			70%			50%			30%			10%			0
□w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
□fc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### WEC AND CCEC

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

<input type="checkbox"/> cc	80%	70%	50%	30%	10%	0
<input type="checkbox"/> w	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	0
<input type="checkbox"/> fc	20%	20%	20%	20%	20%	0
RCR	RCR:Room Cavity Ratio					Wall Exitance Coefficients(WEC)
0.0						
1.0	.208 .118 .037	.201 .115 .036	.187 .107 .034	.175 .101 .032	.163 .095 .031	
2.0	.195 .107 .033	.189 .104 .032	.177 .099 .031	.167 .094 .029	.157 .089 .028	
3.0	.182 .097 .029	.177 .095 .028	.167 .090 .027	.157 .086 .026	.149 .082 .025	
4.0	.169 .088 .026	.165 .086 .026	.156 .083 .025	.148 .080 .024	.141 .076 .023	
5.0	.158 .081 .023	.154 .079 .023	.147 .076 .023	.140 .074 .022	.133 .071 .021	
6.0	.149 .074 .021	.145 .073 .021	.138 .071 .021	.132 .069 .020	.126 .066 .020	
7.0	.140 .069 .020	.137 .068 .019	.131 .066 .019	.125 .064 .019	.120 .062 .018	
8.0	.132 .064 .018	.129 .064 .018	.124 .062 .018	.119 .060 .017	.114 .059 .017	
9.0	.125 .060 .017	.122 .060 .017	.118 .058 .016	.113 .057 .016	.109 .055 .016	
10.0	.118 .057 .016	.116 .056 .016	.112 .055 .015	.108 .054 .015	.104 .052 .015	

<input type="checkbox"/> cc	80%	70%	50%	30%	10%	0
<input type="checkbox"/> w	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	50% 30% 10%	0
<input type="checkbox"/> fc	20%	20%	20%	20%	20%	0
RCR	RCR:Room Cavity Ratio					Ceiling Cavity Exitance Coefficients(CCEC)
0.0	.201 .201 .201	.172 .172 .172	.117 .117 .117	.067 .067 .067	.022 .022 .022	
1.0	.184 .168 .153	.157 .144 .132	.108 .099 .091	.062 .057 .053	.020 .018 .017	
2.0	.170 .143 .120	.146 .123 .104	.100 .085 .073	.058 .050 .043	.018 .016 .014	
3.0	.158 .124 .097	.136 .107 .084	.093 .075 .059	.054 .044 .035	.017 .014 .011	
4.0	.148 .110 .081	.127 .095 .070	.087 .066 .049	.050 .039 .029	.016 .013 .010	
5.0	.139 .098 .069	.119 .085 .060	.082 .059 .042	.048 .035 .025	.015 .011 .008	
6.0	.131 .089 .059	.113 .077 .052	.078 .054 .037	.045 .032 .022	.015 .010 .007	
7.0	.124 .082 .052	.107 .071 .045	.074 .050 .032	.043 .029 .019	.014 .010 .006	
8.0	.118 .075 .046	.101 .065 .040	.070 .046 .029	.041 .027 .017	.013 .009 .006	
9.0	.112 .070 .042	.096 .061 .036	.067 .043 .026	.039 .025 .015	.013 .008 .005	
10.0	.107 .066 .038	.092 .057 .033	.064 .040 .024	.037 .024 .014	.012 .008 .005	

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### UGR(Unified Glare Rating) Table

NAME: FW26212424B0015					TYPE: FW26212424B0015			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.:					SUR.: 0.026*1			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	2H	16.6	17.6	16.8	17.8	18.0	17.2	18.2	17.5	18.4	18.6
	3H	17.9	18.8	18.2	19.0	19.3	18.5	19.4	18.8	19.6	19.9
	4H	18.4	19.3	18.7	19.5	19.8	19.1	20.0	19.4	20.2	20.5
	6H	18.7	19.6	19.0	19.8	20.1	19.7	20.5	20.0	20.8	21.1
	8H	18.8	19.6	19.1	19.9	20.2	20.0	20.8	20.3	21.0	21.3
	12H	18.8	19.6	19.1	19.9	20.2	20.2	21.0	20.6	21.3	21.6
4H	2H	17.3	18.2	17.6	18.4	18.7	17.8	18.6	18.1	18.9	19.1
	3H	18.8	19.6	19.2	19.9	20.2	19.2	20.0	19.6	20.3	20.6
	4H	19.5	20.2	19.9	20.5	20.9	20.0	20.7	20.4	21.0	21.4
	6H	19.9	20.6	20.3	20.9	21.3	20.7	21.4	21.1	21.7	22.1
	8H	20.1	20.6	20.5	21.0	21.4	21.1	21.7	21.5	22.1	22.5
	12H	20.1	20.6	20.5	21.0	21.4	21.4	22.0	21.9	22.4	22.8
8H	4H	19.8	20.4	20.3	20.8	21.2	20.3	20.9	20.7	21.3	21.7
	6H	20.5	21.0	20.9	21.4	21.8	21.2	21.7	21.7	22.1	22.6
	8H	20.7	21.1	21.2	21.6	22.0	21.7	22.1	22.2	22.6	23.0
	12H	20.8	21.2	21.3	21.6	22.1	22.2	22.5	22.7	23.0	23.5
12H	4H	19.9	20.4	20.3	20.8	21.2	20.3	20.9	20.8	21.3	21.7
	6H	20.6	21.0	21.1	21.5	21.9	21.3	21.7	21.8	22.2	22.6
	8H	20.9	21.2	21.4	21.7	22.2	21.8	22.2	22.3	22.6	23.1
Variations with the observer position at spacings(CIE Pub.117):											
S = 1.0H		+ 0.3 / - 0.3					+ 0.2 / - 0.3				
1.5H		+ 0.2 / - 0.3					+ 0.1 / - 0.1				
2.0H		+ 0.2 / - 0.5					+ 0.2 / - 0.3				

CIE Pub.117, 164.8 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -6.3)  
Area: 0.026 m2

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

### UTILIZATION FACTORS TABLE

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	77	69	64	76	68	64	75	68	64	59
0.80	85	77	72	84	77	72	83	76	72	67
1.00	91	83	79	90	83	78	88	83	78	72
1.25	96	89	84	95	88	84	92	87	83	77
1.50	99	93	88	98	92	88	95	90	87	81
2.00	104	98	94	102	97	93	99	94	91	85
2.50	106	101	97	104	99	96	101	97	94	87
3.00	108	104	100	106	102	99	102	99	96	89
4.00	111	107	104	109	105	102	104	102	100	91
5.00	112	109	107	110	107	105	106	104	102	93
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

### ISOCANDELA DIAGRAM

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:




C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:



### AAI Figure

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks:

ISOLUX DIAGRAM

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:



C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

## LED Avg.L Report

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	592
L_0~180 (75) av	489
L_0~180 (85) av	239
L_90~270 (65) av	591
L_90~270 (75) av	493
L_90~270 (85) av	602
L_45 (65) av	739
L_45 (75) av	600
L_45 (85) av	569

Standard: GB/T 29293-2012

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature: 25.3DEG  
Operators:  
Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity: 65.0%  
Test Distance: 5.749m [K=1.0000]  
Remarks:

### Planar Illuminance Curve



C Range: 0 - 360DEG  
 C Interval: 22.5DEG  
 Test Speed: HIGH  
 Temperature: 25.3DEG  
 Operators:  
 Test Date: 2021-11-16

☐ Range: 0 - 180DEG  
☐ Interval: 2.0DEG  
 Test System: EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
 Humidity: 65.0%  
 Test Distance: 5.749m [K=1.0000]  
 Remarks:

## LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: FW26212424B0015	TYPE: FW26212424B0015	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.026*1	Shielding Angle:

Table--1

UNIT: cd

C (DEG) □ (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	365	365	365	365	365	365	365	365	365	365	365	365	365	365	365	365			
5	303	375	442	513	562	599	548	443	330	262	218	196	192	205	228	266			
10	167	248	363	557	686	728	568	385	191	133	108	97.5	95.9	105	122	154			
15	106	155	236	385	507	571	445	273	125	87.1	71.4	65.3	64.6	71.7	83.4	110			
20	60.8	79.1	105	156	201	238	200	151	66.1	49.5	41.2	39.0	38.8	44.1	51.7	66.9			
25	42.5	53.9	68.7	95.6	120	138	126	104	46.9	36.6	31.4	29.7	30.0	34.1	40.9	52.6			
30	28.3	34.0	41.5	53.8	65.1	75.2	73.0	65.1	30.7	25.8	22.3	21.1	21.5	24.8	29.9	39.4			
35	22.9	27.0	32.3	39.9	46.6	54.3	54.3	50.4	24.4	21.1	18.1	17.3	17.6	20.7	25.0	33.4			
40	17.6	20.5	24.2	28.2	32.0	37.7	39.0	36.8	18.0	16.0	13.9	13.2	13.3	15.9	19.8	26.5			
45	15.0	17.4	20.3	23.0	25.8	30.7	32.4	30.9	15.1	13.5	11.8	11.1	11.3	13.4	17.1	23.1			
50	12.1	13.9	15.8	17.3	19.0	22.9	24.9	24.2	11.7	10.6	9.27	8.66	8.67	10.47	13.6	18.8			
55	10.6	12.2	13.5	14.5	15.7	19.1	21.0	20.8	10.1	9.07	7.83	7.09	7.09	8.65	11.55	16.2			
60	8.45	9.79	10.8	11.2	12.0	14.7	16.6	16.7	7.90	6.98	5.83	5.05	4.99	6.11	8.53	12.55			
65	7.09	8.34	9.12	9.44	10.06	12.3	14.1	14.16	6.58	5.64	4.56	3.79	3.68	4.51	6.52	9.99			
70	5.09	6.23	6.85	7.12	7.61	9.32	10.64	10.64	4.67	3.70	2.73	2.07	1.91	2.36	3.70	6.42			
75	3.77	4.84	5.42	5.76	6.24	7.57	8.53	8.39	3.45	2.45	1.62	1.10	0.94	1.15	2.06	4.12			
80	1.88	2.78	3.38	3.80	4.21	5.10	5.53	5.02	1.70	0.88	0.39	0.15	0.07	0.10	0.36	1.33			
85	0.80	1.55	2.14	2.64	3.00	3.59	3.65	2.94	0.70	0.22	0.05	0.03	0.02	0.03	0.05	0.23			
90	0.01	0.27	0.67	1.07	1.35	1.61	1.37	0.68	0.01	0.02	0.02	0.03	0.03	0.04	0.04	0.03			
95	0.01	0.03	0.12	0.34	0.51	0.61	0.39	0.04	0.01	0.02	0.03	0.04	0.04	0.05	0.06	0.05			
100	0.03	0.02	0.02	0.02	0.02	0.03	0.04	0.04	0.02	0.04	0.05	0.06	0.06	0.07	0.08	0.07			
105	0.04	0.03	0.02	0.02	0.02	0.03	0.04	0.06	0.03	0.05	0.06	0.07	0.08	0.09	0.10	0.09			
110	0.07	0.05	0.04	0.04	0.04	0.05	0.07	0.09	0.06	0.07	0.08	0.09	0.10	0.12	0.14	0.13			
115	0.08	0.07	0.06	0.05	0.05	0.06	0.09	0.12	0.07	0.09	0.10	0.11	0.12	0.15	0.16	0.16			
120	0.11	0.09	0.08	0.07	0.07	0.09	0.12	0.16	0.10	0.11	0.13	0.14	0.16	0.20	0.21	0.21			
125	0.13	0.11	0.10	0.09	0.09	0.11	0.14	0.20	0.11	0.13	0.15	0.17	0.19	0.24	0.26	0.25			
130	0.18	0.14	0.13	0.12	0.12	0.15	0.19	0.25	0.15	0.17	0.20	0.24	0.27	0.33	0.35	0.34			
135	0.22	0.18	0.16	0.15	0.15	0.18	0.22	0.30	0.18	0.21	0.24	0.30	0.35	0.43	0.44	0.42			
140	0.30	0.25	0.22	0.20	0.21	0.24	0.30	0.40	0.25	0.30	0.35	0.45	0.54	0.66	0.66	0.61			
145	0.39	0.32	0.27	0.25	0.26	0.31	0.38	0.50	0.32	0.38	0.47	0.61	0.73	0.89	0.88	0.79			
150	0.60	0.49	0.42	0.38	0.39	0.46	0.56	0.75	0.47	0.56	0.71	0.96	1.16	1.40	1.35	1.17			
155	0.81	0.67	0.58	0.53	0.54	0.63	0.76	0.99	0.62	0.74	0.96	1.29	1.58	1.87	1.77	1.52			
160	1.27	1.09	0.95	0.89	0.90	1.02	1.19	1.49	0.97	1.13	1.43	1.94	2.38	2.74	2.56	2.20			
165	1.68	1.47	1.32	1.25	1.26	1.39	1.59	1.93	1.30	1.48	1.79	2.36	2.91	3.26	3.07	2.69			
170	2.35	2.17	2.01	1.97	2.00	2.18	2.37	2.72	1.92	2.12	2.35	2.76	3.21	3.55	3.59	3.40			
175	2.72	2.62	2.52	2.56	2.62	2.84	2.98	3.26	2.39	2.56	2.77	3.08	3.33	3.65	3.82	3.81			
180	2.88	2.96	3.04	3.31	3.45	3.71	3.81	4.02	2.90	2.94	3.06	3.29	3.47	3.69	3.81	4.01			

C Range: 0 - 360DEG  
C Interval: 22.5DEG  
Test Speed: HIGH  
Temperature:25.3DEG  
Operators:  
Test Date:2021-11-16

□ Range: 0 - 180DEG  
□ Interval: 2.0DEG  
Test System:EVERFINE GO-2000B\_V1 SYSTEM V2.00.450  
Humidity:65.0%  
Test Distance:5.749m [K=1.0000]  
Remarks: