


LUMINAIRE PHOTOMETRIC TEST REPORT


NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 194.57 lm/W
MODEL	6500K	Imax (cd)	135.9	S/MH(C0/180)	1.29	
NOMINAL POWER(W)	2.25	LOR(%)	100.0	S/MH(C90/270)	1.27	
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	415.11	□ UP,DN(C0-180)	0.7,51.5	
NOMINAL FLUX(lm)	9.22457	CIE CLASS	DIRECT	□ UP,DN(C180-360)	0.7,47.1	
LAMPS INSIDE	45	□ up (%)	1.4	CIBSE SHR NOM	1.25	
TEST VOLTAGE(V)	24	□ down (%)	98.6	CIBSE SHR MAX	1.35	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2022-03-24

□ Range: 0 - 180DEG
 □ Interval: 2.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
 Humidity:65.0%
 Test Distance:5.749m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

°	C0	C45	C90	C135	C180	C225	C270	C315	°	□ zone	□ total	%lum, lamp
10	134.3	134.8	134.8	134.5	133.9	133.5	133.5	133.8	0- 10	12.89	12.89	3.11,3.11
20	128.7	129.7	129.8	129.1	127.9	127.0	126.8	127.6	10- 20	37.20	50.09	12.1,12.1
30	119.0	120.5	120.8	119.7	117.8	116.3	116.1	117.2	20- 30	57.12	107.2	25.8,25.8
40	105.1	107.3	107.9	106.4	103.7	101.6	101.2	102.7	30- 40	70.05	177.3	42.7,42.7
50	87.15	90.15	91.04	89.21	85.68	82.90	82.20	84.10	40- 50	74.03	251.3	60.5,60.5
60	65.43	69.18	70.45	68.35	63.95	60.41	59.42	61.60	50- 60	67.97	319.3	76.9,76.9
70	40.79	45.09	46.66	44.41	39.42	35.29	34.07	36.35	60- 70	52.15	371.4	89.5,89.5
80	16.65	20.50	21.88	19.94	15.54	12.08	10.82	12.71	70- 80	29.47	400.9	96.6,96.6
90	0.1549	3.079	3.598	2.924	0.6636	1.082	0.4629	0.6414	80- 90	8.409	409.3	98.6,98.6
100	0.3460	0.3069	0.4053	0.3719	0.3014	0.3921	0.3617	0.3264	90-100	0.7503	410.0	98.8,98.8
110	0.6282	0.5606	0.5468	0.5758	0.5576	0.5731	0.5902	0.5621	100-110	0.4695	410.5	98.9,98.9
120	0.9080	0.8174	0.8108	0.8424	0.8209	0.8084	0.8208	0.8002	110-120	0.6932	411.2	99.1,99.1
130	1.157	1.060	1.049	1.085	1.058	1.032	1.025	1.012	120-130	0.8450	412.1	99.3,99.3
140	1.354	1.262	1.246	1.297	1.252	1.222	1.199	1.200	130-140	0.8959	412.9	99.5,99.5
150	1.506	1.443	1.418	1.466	1.407	1.381	1.342	1.362	140-150	0.8382	413.8	99.7,99.7
160	1.629	1.588	1.601	1.602	1.551	1.526	1.513	1.517	150-160	0.6882	414.5	99.8,99.8
170	1.750	1.737	1.760	1.738	1.708	1.690	1.699	1.691	160-170	0.4630	414.9	100,100
180	1.876	1.871	1.896	1.881	1.878	1.875	1.896	1.881	170-180	0.1699	415.1	100,100
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 221.83 lm

%lum = 53.4%

%lamp = 53.4%

Conical surface Flux(120deg): 319.26 lm

%lum = 76.9%


%lamp = 76.9%

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2022-03-24

□ Range: 0 - 180DEG
□ Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	9809	14994
80	9614	12596
75	11915	14152
70	11959	13639
65	13246	14489
60	13122	14086
55	13788	14504
50	13594	14159
45	13949	14367


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity: 65.0%
Test Distance: 5.749m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:

□cc	80%			70%			50%			30%			10%			0
□w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
□fc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															
	Coefficients of Utilization(CU)															
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.10	1.10	1.10	1.05	1.05	1.05	1.01	1.01	1.01	.99
1.0	1.03	.99	.95	1.01	.97	.93	.96	.93	.90	.92	.90	.87	.88	.86	.84	.82
2.0	.90	.83	.77	.88	.81	.76	.84	.79	.74	.80	.76	.72	.77	.74	.70	.68
3.0	.79	.70	.64	.77	.69	.63	.74	.67	.62	.71	.65	.60	.68	.63	.59	.57
4.0	.69	.61	.54	.68	.60	.53	.65	.58	.52	.63	.57	.52	.60	.55	.51	.48
5.0	.62	.53	.46	.61	.52	.46	.58	.51	.45	.56	.50	.44	.54	.49	.44	.42
6.0	.56	.47	.40	.55	.46	.40	.53	.45	.39	.51	.44	.39	.49	.43	.38	.36
7.0	.50	.42	.35	.49	.41	.35	.48	.40	.35	.46	.39	.34	.45	.39	.34	.32
8.0	.46	.37	.31	.45	.37	.31	.44	.36	.31	.42	.36	.31	.41	.35	.30	.28
9.0	.42	.34	.28	.41	.33	.28	.40	.33	.28	.39	.32	.28	.38	.32	.27	.26
10.0	.39	.31	.25	.38	.31	.25	.37	.30	.25	.36	.30	.25	.35	.29	.25	.23



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2022-03-24

□ Range: 0 - 180DEG
□ Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks:

WEC AND CCEC

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:

<input type="checkbox"/> cc	80%			70%			50%			30%			10%			0	
<input type="checkbox"/> w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
<input type="checkbox"/> fc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.314	.179	.057	.306	.175	.056	.292	.168	.054	.279	.161	.052	.267	.155	.050		
2.0	.295	.162	.050	.288	.159	.049	.276	.153	.048	.264	.148	.046	.254	.143	.045		
3.0	.273	.145	.043	.267	.143	.043	.256	.139	.042	.245	.134	.041	.236	.131	.040		
4.0	.251	.131	.038	.246	.129	.038	.236	.125	.037	.227	.122	.037	.219	.119	.036		
5.0	.232	.118	.034	.228	.117	.034	.219	.114	.034	.211	.111	.033	.203	.108	.033		
6.0	.215	.108	.031	.211	.107	.031	.203	.104	.030	.196	.102	.030	.189	.099	.030		
7.0	.200	.099	.028	.196	.098	.028	.189	.096	.028	.183	.094	.027	.177	.092	.027		
8.0	.187	.091	.026	.183	.090	.026	.177	.089	.025	.171	.087	.025	.166	.085	.025		
9.0	.175	.085	.024	.172	.084	.024	.166	.082	.023	.161	.081	.023	.156	.079	.023		
10.0	.164	.079	.022	.162	.078	.022	.157	.077	.022	.152	.075	.021	.147	.074	.021		

<input type="checkbox"/> cc	80%			70%			50%			30%			10%			0	
<input type="checkbox"/> w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
<input type="checkbox"/> fc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.201	.201	.201	.172	.172	.172	.117	.117	.117	.067	.067	.067	.022	.022	.022		
1.0	.191	.167	.145	.164	.143	.125	.112	.099	.086	.064	.057	.050	.021	.018	.016		
2.0	.183	.143	.108	.157	.123	.094	.108	.085	.065	.062	.049	.038	.020	.016	.012		
3.0	.176	.125	.085	.151	.108	.074	.104	.075	.052	.060	.044	.030	.019	.014	.010		
4.0	.168	.112	.069	.144	.097	.060	.099	.067	.042	.057	.039	.025	.018	.013	.008		
5.0	.161	.102	.058	.138	.088	.050	.095	.061	.036	.055	.036	.021	.018	.012	.007		
6.0	.154	.093	.050	.132	.081	.043	.091	.057	.031	.053	.033	.018	.017	.011	.006		
7.0	.147	.086	.044	.126	.075	.038	.087	.053	.027	.051	.031	.016	.016	.010	.005		
8.0	.140	.081	.040	.121	.070	.035	.084	.049	.025	.049	.029	.015	.016	.010	.005		
9.0	.134	.076	.036	.116	.066	.032	.080	.046	.022	.047	.027	.013	.015	.009	.004		
10.0	.129	.071	.033	.111	.062	.029	.077	.044	.021	.045	.026	.012	.015	.008	.004		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

NAME: 2835 IP20					TYPE: 2835 90LED 24V			WEIGHT:			
SPEC.:					DIM.:			SERIAL No.:			
MFR.:					SUR.: 0.01*0.5			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H	25.1	26.6	25.4	26.9	27.1	25.4	26.9	25.7	27.1	27.4	
	26.7	28.1	27.0	28.4	28.6	27.1	28.5	27.4	28.8	29.0	
	27.3	28.6	27.6	28.9	29.2	27.8	29.1	28.2	29.4	29.7	
	27.7	29.0	28.1	29.3	29.6	28.4	29.6	28.7	29.9	30.2	
	27.8	29.0	28.2	29.3	29.7	28.6	29.8	28.9	30.1	30.4	
	27.9	29.0	28.2	29.4	29.7	28.7	29.9	29.1	30.2	30.5	
4H 2H	25.8	27.2	26.2	27.4	27.7	26.0	27.4	26.4	27.6	27.9	
	27.6	28.7	28.0	29.1	29.4	27.9	29.1	28.3	29.4	29.7	
	28.3	29.4	28.7	29.7	30.1	28.8	29.8	29.2	30.2	30.6	
	28.9	29.8	29.3	30.2	30.6	29.5	30.4	29.9	30.8	31.2	
	29.0	29.9	29.5	30.3	30.7	29.7	30.6	30.2	31.0	31.4	
	29.1	29.9	29.6	30.3	30.8	29.9	30.7	30.4	31.2	31.6	
8H 4H	28.6	29.5	29.1	29.9	30.3	29.1	29.9	29.5	30.3	30.7	
	29.4	30.1	29.8	30.5	31.0	29.9	30.7	30.4	31.1	31.5	
	29.6	30.3	30.1	30.7	31.2	30.3	30.9	30.8	31.4	31.9	
	29.8	30.4	30.3	30.8	31.4	30.6	31.2	31.1	31.6	32.1	
12H 4H	28.7	29.5	29.1	29.9	30.3	29.1	29.9	29.5	30.3	30.7	
	29.4	30.1	29.9	30.5	31.0	30.0	30.6	30.5	31.1	31.6	
	29.8	30.3	30.3	30.8	31.3	30.4	31.0	30.9	31.4	31.9	
Variations with the observer position at spacings(CIE Pub.117):											
S = 1.0H	+ 0.1 / - 0.2					+ 0.1 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					
2.0H	+ 0.2 / - 0.4					+ 0.1 / - 0.3					

CIE Pub.117, 415.1 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -3.1)
Area: 0.01 m2

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks:


```

Range: 0 - 180DEG
Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks:

```

ISOCANDELA DIAGRAM

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity: 65.0%
Test Distance: 5.749m [K=1.0000]
Remarks:

AAI Figure

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
 Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
 Humidity:65.0%
 Test Distance:5.749m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks:

LED Avg.L Report

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	12457
L_0~180 (75) av	10682
L_0~180 (85) av	7186
L_90~270 (65) av	12517
L_90~270 (75) av	10773
L_90~270 (85) av	8213
L_45 (65) av	12502
L_45 (75) av	10739
L_45 (85) av	8219

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators:
 Test Date: 2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
 Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.450
 Humidity: 65.0%
 Test Distance: 5.749m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2022-03-24

☐ Range: 0 - 180DEG
☐ Interval: 2.0DEG
Test System: EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity: 65.0%
Test Distance: 5.749m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 2835 IP20	TYPE: 2835 90LED 24V	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.: 0.01*0.5	Shielding Angle:

Table--1

UNIT: cd

C (DEG) □ (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	136	136	136	136	136	136	136	136	136	136	136	136	136	136	136	136			
5	136	136	136	136	136	136	136	136	136	135	135	135	135	135	135	136	136		
10	134	135	135	135	135	135	134	134	134	134	134	133	133	134	134	134			
15	133	133	133	133	133	133	133	132	132	132	131	131	131	131	132	132			
20	129	129	130	130	130	130	129	128	128	127	127	127	127	127	128	128			
25	125	126	127	127	127	126	126	125	124	124	123	123	123	123	124	125			
30	119	120	121	121	121	121	120	119	118	117	116	116	116	116	117	118			
35	114	115	116	116	116	116	115	114	113	112	111	110	111	111	112	113			
40	105	106	107	108	108	108	106	105	104	102	102	101	101	102	103	104			
45	98.4	99.9	101	102	102	101	100.0	98.6	97.0	95.5	94.6	93.9	94.1	94.5	95.8	96.9			
50	87.1	88.9	90.2	91.1	91.0	90.6	89.2	87.6	85.7	83.9	82.9	82.0	82.2	82.7	84.1	85.5			
55	78.9	80.9	82.2	83.3	83.2	82.8	81.3	79.6	77.4	75.4	74.3	73.4	73.5	74.0	75.5	77.0			
60	65.4	67.7	69.2	70.4	70.4	70.0	68.4	66.4	63.9	61.7	60.4	59.3	59.4	59.9	61.6	63.2			
65	55.8	58.2	59.8	61.2	61.2	60.9	59.1	57.0	54.4	52.0	50.6	49.3	49.5	50.0	51.7	53.5			
70	40.8	43.4	45.1	46.6	46.7	46.3	44.4	42.2	39.4	36.9	35.3	34.0	34.1	34.6	36.4	38.2			
75	30.8	33.3	35.0	36.5	36.6	36.3	34.4	32.2	29.4	26.8	25.3	24.0	24.0	24.5	26.3	28.1			
80	16.6	19.0	20.5	21.8	21.9	21.6	19.9	18.1	15.5	13.3	12.1	10.9	10.8	11.2	12.7	14.3			
85	8.53	10.7	12.1	13.0	13.1	12.9	11.6	10.1	7.26	6.45	5.52	4.67	4.39	4.61	5.74	6.97			
90	0.15	2.30	3.08	3.66	3.60	3.51	2.92	2.26	0.66	1.30	1.08	0.73	0.46	0.49	0.64	0.87			
95	0.20	0.43	0.81	1.14	1.22	1.18	0.99	0.76	0.19	0.67	0.62	0.43	0.32	0.33	0.31	0.22			
100	0.35	0.31	0.31	0.37	0.41	0.38	0.37	0.35	0.30	0.31	0.39	0.35	0.36	0.35	0.33	0.31			
105	0.46	0.41	0.40	0.39	0.39	0.39	0.41	0.43	0.40	0.40	0.43	0.44	0.45	0.43	0.41	0.40			
110	0.63	0.58	0.56	0.54	0.55	0.55	0.58	0.60	0.56	0.55	0.57	0.58	0.59	0.58	0.56	0.54			
115	0.75	0.69	0.67	0.65	0.66	0.67	0.69	0.71	0.66	0.66	0.67	0.68	0.69	0.68	0.66	0.64			
120	0.91	0.84	0.82	0.81	0.81	0.82	0.84	0.87	0.82	0.80	0.81	0.82	0.82	0.82	0.80	0.79			
125	1.01	0.95	0.92	0.91	0.91	0.92	0.94	0.97	0.92	0.90	0.90	0.91	0.91	0.90	0.89	0.88			
130	1.16	1.10	1.06	1.05	1.05	1.07	1.09	1.12	1.06	1.04	1.03	1.03	1.03	1.02	1.01	1.02			
135	1.24	1.19	1.14	1.13	1.13	1.16	1.18	1.21	1.14	1.12	1.11	1.11	1.10	1.10	1.09	1.10			
140	1.35	1.31	1.26	1.24	1.25	1.28	1.30	1.33	1.25	1.23	1.22	1.21	1.20	1.20	1.20	1.22			
145	1.42	1.38	1.34	1.32	1.32	1.36	1.37	1.40	1.32	1.30	1.29	1.28	1.25	1.26	1.26	1.29			
150	1.51	1.48	1.44	1.42	1.42	1.46	1.47	1.48	1.41	1.39	1.38	1.37	1.34	1.35	1.36	1.39			
155	1.56	1.54	1.50	1.48	1.49	1.53	1.53	1.54	1.46	1.44	1.44	1.44	1.41	1.41	1.42	1.45			
160	1.63	1.62	1.59	1.57	1.60	1.61	1.60	1.62	1.55	1.53	1.53	1.52	1.51	1.50	1.52	1.54			
165	1.68	1.67	1.64	1.63	1.67	1.66	1.66	1.67	1.61	1.60	1.59	1.59	1.59	1.56	1.58	1.61			
170	1.75	1.75	1.74	1.73	1.76	1.75	1.74	1.76	1.71	1.70	1.69	1.70	1.70	1.68	1.69	1.71			
175	1.80	1.81	1.80	1.80	1.82	1.81	1.81	1.82	1.78	1.77	1.77	1.77	1.78	1.76	1.77	1.79			
180	1.88	1.87	1.87	1.88	1.90	1.88	1.88	1.89	1.88	1.87	1.88	1.88	1.90	1.88	1.88	1.89			

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2022-03-24

□ Range: 0 - 180DEG
□ Interval: 2.0DEG
Test System:EVERFINE GO-2000B_V1 SYSTEM V2.00.450
Humidity:65.0%
Test Distance:5.749m [K=1.0000]
Remarks: